



Corporate Office – 3556 Lake Shore Road, Buffalo, NY 14127
(716) 827-8000 P, (716) 827-7958 F
Erie County Office – 100 Hamburg Street, PO Box 516, East Aurora, NY 14052
Cattaraugus County Office – 8 Martha Street, PO Box 1599, Ellicottville, NY 14731
Chautauqua County Office – 338 Central Ave, Dunkirk, NY 14048
Niagara County Office – 84 Sweeney Street, Suite C-13, N. Tonawanda, NY 14210

**ADDENDUM NO. 1
TO THE
SPECIFICATIONS AND CONTRACT DOCUMENTS

GATES AND PINWOODS PUMP STATIONS
GENERAL CONTRACT**

**SENECA NATION OF INDIANS – HEALTH DEPARTMENT
SALAMANCA NEW YORK**

The Contract Documents are herein amended by this Addendum No. 1 as follows:

Changes/Clarifications to referenced specifications and contract documents include:

1. **DELETE:** Sheet M-104: **INSERT:** Attached Sheet M-104. Four-inch Globe PRV has been changed to a six-inch Globe PRV with associated pipe and fitting changes from four inch to six inch.
2. In the specification Section 400567.36 on page 400567.36-3, subsection 2.1.A.1.a **DELETE:** Ross Valve Co. Model 40WR: **INSERT:** Ross Valve Co. Model 42WR.

**NUSSBAUMER & CLARKE, INC.
CONSULTING ENGINEERS**

Dated: July 29, 2016